



Compliance Statement

Screened Category 6 ISO/IEC, EN & ANSI/TIA Communication Cable

BKT Identification P/N 10151503.* (* = 305m/500m/1000m)

CABLE U/FTP LSHF Cat.6 BKT 455 Eca

Cat. 6, Overall Unscreened Cable with Foil Screened Twisted Pairs


100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, LSHF, Copper Communication Cable

**BKT Elektronik Sp. z o.o.
ul. Łochowska 69,
86-005 Białe Błota, Poland**

Compliance Statement No. 0473-3P-1221314

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6 requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-5-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014, edition 3.1 of IEC 61034-2:2013 and edition 2.0 of IEC 60754-2:2011. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 1st December 2023.


Hoersholm, 1st December 2022


Peter Freiberg Kaas
Test Responsible

3P Third Party Testing ApS
Agern Alle 3
2970 Hørsholm
Denmark

<https://www.3ptest.dk/>

Hoersholm, 1st December 2022


Jens Rytter Petersen
General Manager